



# ENVIRONMENTAL CLAIM VALIDATION SUMMARY

## Shenzhen Lideng Environmental Protection Engineering Co., Ltd

### Bipolar Ionizer PS-501T

**Report Number:**

344034-4710

**Validation Period:**

17 Dec 2024 - 17 Dec 2025

---

**Claim:**

Zero Ozone Emissions – Measured Ozone Emissions from Bipolar Ionizer PS-501T during use phase does not exceed 0.005 ppm as tested by UL 867.

**Method:**

ECVP 2998 Zero Ozone Emissions from Air Cleaners, Third Edition - 2020

**Facility:**

8C, Kechuang Bldg., Quanzhi Science And Technology Innovation Park, Maozhoushan Industrial Park, Houting, Shajing Subdistrict, Shenzhen, Guangdong, 518103, China